

Institut für Baustoffe, Massivbau und Brandschutz

MPA Braunschweig, Beethovenstr. 52, 38106 Braunschweig, Germany

## Certificate of constancy of performance

0761 - CPR - 0478

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product

Powered smoke and heat exhaust ventilators

Jetfan type AUZ 340

Diameter: 340 mm

class according to EN 13501-4:2016: F<sub>300</sub> 60

produced by or for

Novenco Industrivej 22 DK-4700 Næstved Denmark

in the manufacturing plant(s)

Næstved (Denmark).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

## constancy of performance of the construction product.

This certificate contains an annex with one page. It has first been issued on 06-12-2015. It is valid from 06-12-2020 and will remain valid till 26-10-2025, as neither the harmonised specification, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 27-10-2020

Z-3/710/05



## **Axial Smoke Exhaust Ventilators**

## 1. Use and application classes

The ventilator may be mounted as follows:	
<ul> <li>☑ outside of the building without thermal insulation</li> <li>☐ outside of the building including thermal insulation</li> <li>☑ inside the building but outside of the fire zone, without thermal insulation</li> <li>☐ inside the building but outside of the fire zone including thermal insulation</li> <li>☑ inside the fire zone</li> </ul>	
The motor axle shall be orientated as follows:	
<ul> <li>horizontal, floor standing</li> <li>horizontal, wall mounted</li> <li>horizontal, ceiling mounted</li> <li>vertical, Δp upward</li> <li>vertical, Δp downward</li> <li>vertical, wall mounted</li> <li>vertical, ceiling mounted</li> </ul>	
☐ The ventilator may be used for both functions.	
Cooling is necessary.	
2. Minimum functioning time	
In the test the ventilator maintained its function for at least 120 min.	
3. Technical product data	
Diameter	340 mm
Motor maker	WEG
4. Additional information Standards referred to:	
EN 12101-3 EN 13501-4 EN 136	3-1 EN 1363-2 ENV 1363-3
End of the certificate of constancy of performance	