





## Annex of Certificate of constancy of performance

0761-CPR-0129

Annex 2 of 2

<b>Flexible connectors</b>		<b>Basis</b>
<input type="checkbox"/>	Flexible inlet duct on the inlet side	
<input type="checkbox"/>	Flexible inlet duct on the outlet side	
<input type="checkbox"/>	Flexible inlet duct on the inlet and outlet side	
<input type="checkbox"/>	Flexible inlet duct for the cooling air connection	
<b>Cooling air</b>		<b>Basis</b>
<input type="checkbox"/>	The minimum cooling air volume flow rate $C_{Air,\theta}$ depends on the fan's nominal size and nominal power (see operating manual). Maximum cooling air temperature $\theta = 40 \text{ }^\circ\text{C}$	
<b>Starting</b>		<b>Basis</b>
<input type="checkbox"/>	AA oder MA (automatic or manual)	
<b>Snow load, wind load</b>		<b>Basis</b>
<input type="checkbox"/>	Opening under wind load in a defined period of time	
<input type="checkbox"/>	Opening under snow load in a defined period of time	
<b>Accessories</b>		<b>Basis</b>
<input checked="" type="checkbox"/>	Terminal box	3782/045/07
<input checked="" type="checkbox"/>	Bellmouth	3782/045/07
<input checked="" type="checkbox"/>	Safety grid	3782/045/07
<input checked="" type="checkbox"/>	Horizontal mounting brackets	3782/045/07
<input checked="" type="checkbox"/>	Silencer	3782/045/07
<b>Application classes</b>		<b>Basis</b>
<input checked="" type="checkbox"/>	Dual purpose, Ventilation and Smoke extraction	2401/091/16
<input type="checkbox"/>	Variable Speed Drive	

### Technical product data:

Range of diameters	900 mm ... 1,600 mm
Motor maker	WEG oder Leroy Somer

### Standards referred to:

EN 12101-3	EN 13501-4	EN 1363-1	EN 1363-2	ENV 1363-3
------------	------------	-----------	-----------	------------

### Basis:

Test report no. 3782/045/07, 2401/091/16

----- End of the certificate of constancy of performance -----