

Certificate of constancy of performance

0761-CPR-0928

Z-3/710/03 (no. of agreement)

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the

construction product

Powered smoke and heat exhaust ventilators
Axial smoke exhaust ventilator, product family "ZerAx"
Diameter: 250 mm ... 2,000 mm
class according to EN 13501-4:2016: F₂₀₀ 120

produced by or for

NOVENCO Building & Industry A/S
Oeverup Erhvervsvej 50-52
4700 Næstved
Denmark

in the manufacturing plant

Næstved (Denmark).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate has an annex with one page. This certificate was issued 2025-12-08 and will remain valid until 2030-12-07, as neither the harmonised standard, the construction product, the AVCP method nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.
The certificate was first issued on 2021-01-26.

Braunschweig

Dipl.-Ing. Petra Aeissen
(Deputy Head of certification body)

Annex of Certificate of constancy of performance

0761-CPR-0928

Annex 1 of 1

1. Series

The product family "ZerAx" includes units of the series:

☒ AZN^{1), 5)}

☒ AZL¹⁾

☒ AZT^{1), 2)}

☒ AUZ^{3), 4)}

☒ Variable Frequency Drive

2. Classification

Class	Temperature (°C)	Time (min)
F ₂₀₀	200	120

3. Classification

Accessories		Basis
<input checked="" type="checkbox"/>	Vertical mounting plate	see below
<input checked="" type="checkbox"/>	Grille	see below
<input checked="" type="checkbox"/>	Horizontal mounting feet	see below
<input checked="" type="checkbox"/>	Inlet cone	see below
<input checked="" type="checkbox"/>	Extension ducts	see below
<input checked="" type="checkbox"/>	Deflector	see below
<input checked="" type="checkbox"/>	Blow-off cone	see below
<input checked="" type="checkbox"/>	Silencer	see below
<input checked="" type="checkbox"/>	Diffuser	see below
<input checked="" type="checkbox"/>	Flexible connections	see below

Basis:

¹⁾Test report No.: 2401/121/19-C6.2-MPA BS of 2020-12-13, ²⁾Test report No.: 2401/265/16-C5.2-MPA BS of 2017-06-15, ³⁾Test report No.: 2400/289/15-C5.2-MPA BS of 2015-11-27, ⁴⁾Test report No.: 2400/199/15-C5.2-MPA BS of 2015-11-18, ⁵⁾Test report No.: 2401/805/22-C6.2-MPA BS of 2023-10-12, 2400/303/17, 2400/456/17, 2401/873/22

----- End of the certificate of constancy of performance -----