## Certificate of constancy of performance

0761-CPR-0928

Z-3/710/03 (no. of agreement)



Institut für Baustoffe, Massivbau und Brandschutz

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the

construction product

Powered smoke and heat exhaust ventilators Axial smoke exhaust ventilator, product family "ZerAx" Diameter: 250 mm ... 2,000 mm class according to EN 13501-4:2016: F<sub>200</sub> 120

produced by or for

NOVENCO Building & Industry A/S Industrivej 22 4700 Næstved Denmark

in the manufacturing plant

### Næstved (Denmark).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

#### EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### constancy of performance of the construction product.

This certificate has an annex with one page. It was first issued on 2021-01-26. The validity begins on 2023-12-11 and will remain valid until 2026-01-25, as neither the harmonised standard, the construction product, the AVCP method nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 2023-12-11

Dr.-Ing. Sven Lehmberg (Head of certification body)



# Annex of Certificate of constancy of performance

0761-CPR-0928

Annex 1 of 1

Axial smoke exhaust ventilator

## Institut für Baustoffe, Massivbau und Brandschutz

Materialprüfanstalt

für das Bauwesen

### 1. Series

The product family "ZerAx" includes units of the series:

AZN¹), 5)

 $\boxtimes AZL^{1)}$ 

AUZ<sup>3), 4)</sup>

□ Variable Frequency Drive

### 2. Classification

Class	Temperature (°C)	Time (min)
F <sub>200</sub>	200	120

### Basis:

<sup>1)</sup>Test report No.: 2401/112/19-C6.2-MPA BS of 2020-12-13 <sup>2)</sup>Test report No.: 2401/265/16-C5.2-MPA BS of 2017-06-15 <sup>3)</sup>Test report No.: 2400/289/15-C5.2-MPA BS of 2015-11-27 <sup>4)</sup>Test report No.: 2400/199/15-C5.2-MPA BS of 2015-11-18 <sup>5)</sup>Test report No.: 2401/805/22-C6.2-MPA BS of 2023-10-12

End of the certificate of constancy of performance -----